

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
MALAPARAMBA
KOZHIKODE
Ph: 0495 2964751,
E-mail : qualitysdmalaparamba@gmail.com



TEST REPORT

No -TC105592200000430P

Date of issue: 02/12/2022

Customer Name & Address	1.Date of Receipt	: 30/11/2022
HILLVIEW INTERNATIONAL SCHOOL C/O MANAGER KODATHAI BAZAR P.O THAMARASSERY	2. Sample condition	: FIT FOR ANALYSIS
	3.Sampling done by	: PARTY
	4.Sample code	: 2632/22
	5.Source of sample	: OPEN WELL
	6.Sample quantity	: 1 LTR
	7.Test performing dates	
	From : 30/11/2022	To : 02/12/2022

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Colour	Pt Co. unit	IS 3025 (part 4)-2021	-	<5.0
2	Odour		IS 3025 (part 5)-2018	Agreeable	Agreeable
3	Turbidity	(NTU)	IS 3025 (part 10)-1984 (Reaffirmed 2017)	1	<0.5
4	pH at --- °C	-	IS 3025 (PART 11)-2022	6.5 to 8.5	6.40
5	Alkalinity	(mg/L)	IS 3025 (PART 23)-1986 (Reaffirmed 2019)	200	ND
6	Total Dissolved Solids(TDS)	(mg/L)	IS 3025 (part 16)-1984 (Reaffirmed 2017)	500	<5.0
7	Total Hardness (as CaCO ₃)	(mg/L)	IS 3025 (part 21)-2009 (Reaffirmed 2019)	200	<5.0
8	Calcium (as Ca)	(mg/L)	IS 3025 (part 40)-1991 (Reaffirmed 2019)	75	<5.0
9	Magnesium (as Mg)	(mg/L)	IS 3025 (part 46)-1994 (Reaffirmed 2019)	30	<5.0
10	Chloride (as Cl)	(mg/L)	IS 3025 (part 32)-1988 (Reaffirmed 2019)	250	ND

ND: - Not Done

NB: - The results stated above related only to the samples(S) submitting for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analyzed By: Chemist

End of Report

Authorized By : Deputy Quality Manager



DEPUTY QUALITY MANAGER
KERALA WATER AUTHORITY
SUB DISTRICT LABORATORY
KOZHIKODE